



Stoughton Utilities

600 South Fourth Street
P.O. Box 383
Stoughton, WI 53589-0383

Serving Electric, Water & Wastewater Needs Since 1886

STOUGHTON UTILITIES POLICIES APPROVED BY THE STOUGHTON UTILITIES COMMITTEE AND THE STOUGHTON COMMON COUNCIL

October 28, 2003

Stoughton Utilities Spill Prevention And Countermeasures
(SPCC) Plan



Office 608-873-3379
Fax 608-873-4878
stoughtonutilities.com





Spill Prevention Control and Countermeasures Plan

STOUGHTON MUNICIPAL UTILITIES
600 South Fourth Street
Stoughton, WI

September 2003

ALPHA TERRA SCIENCE, INC. OFFICES

1237 South Pilgrim Road
Plymouth, WI 53073
Phone: (920) 892-2444
Fax: (920) 892-2620

1642 S. County Road O
Mosinee, WI 54455
Phone: (715) 457-2944
Fax: (715) 457-6663

EMERGENCY INFORMATION

Facility Owner, Address, and Telephone:

UTILITIES OFFICE (Electric, Wastewater, and Water Utilities)

Stoughton Municipal Utilities
600 South Fourth Street
Stoughton, WI 53589
(606) 873-3379

NORTH Substation

302 CTH B
Stoughton, WI

SOUTH Substation

Aaker & Taylor Lane
Stoughton, WI

EAST Substation

1200 East South Street
Stoughton, WI

WASTEWATER TREATMENT Facility

700 Mandt Park Drive
Stoughton, WI

Stoughton Municipal Utilities Facility Contacts:

<u>Name</u>	<u>Title</u>	<u>Telephone/Pager</u>
Robert Kardasz, P. E.	Facility Response Coord. & Director	608-873-3379 (work) 608-235-9476 (cell) 608-873-6196 (home)
Sean O Grady	Alt. Fac. Resp. Coord. & Superintendent	608-873-3379 (work) 608-575-3732 (cell) 608-873-3892 (home)
Craig Wood	Alt. Fac. Resp. Coord. & Supervisor	608-873-3379 (work) 608-220-8569 (cell) 608-873-4482 (home)
Brian G. Erickson	Alt. Fac. Resp. Coord. & Wastewater Systems Supv.	608-873-3379 (work) 608-220-9209 (cell) 608-873-6521 (home)

Table of Contents

Emergency Information.....	i
SPCC Review Page.....	iii
Management Approval.....	iv
Spill History.....	v
Certification of Licensed Professional Engineer.....	vi
Introduction.....	1
General Description.....	3
40 CFR 112.7 (a) – General Requirements.....	4
112.7 (a) (1) Discussion of Facility’s Conformance with 40 CFR 112.7.....	4
112.7 (a) (2) Discussion of Allowed Deviations.....	4
112.7 (a) (3) Facility Description, Materials Stored, and Discharge Prevention Considerations.....	5
112.7 (a) (3) (i) Type of Oil in Each Container/Storage Capacity.....	5
112.7 (a) (3) (ii) Discharge Prevention Measures.....	5
112.7 (a) (3) (iii) Discharge or Drainage Controls.....	5
112.7 (a) (3) (iv) Spill Response – Countermeasures for Discharge.....	7
112.7 (a) (3) (v) Methods of Disposal.....	9
112.7 (a) (3) (vi) Contact List.....	9
112.7 (a) (4) Spill Reporting Information.....	11
40 CFR 112.7 (b) – Potential Equipment Failures Resulting in Spills.....	11
40 CFR 112.7 (c) – Containment and Diversionary Structures.....	12
112.7 (c) (1) Onshore Facilities.....	12
112.7 (c) (2) Offshore Facilities.....	14
40 CFR 112.7 (d) – Demonstration of Practicability.....	14
40 CFR 112.7 (e) – Inspections and Test Records.....	14
40 CFR 112.7 (f) – Personnel Training and Spill Prevention Procedures.....	14
40 CFR 112.7 (g) – Security.....	15
112.7 (g) (1) Security Fence.....	15
112.7 (g) (2) Master Flow and Drain Valves.....	15
112.7 (g) (3) Lock Starter Controls.....	15
112.7 (g) (4) Cap Loading/Unloading Connections During Standby.....	15
112.7 (g) (5) Lighting.....	16
40 CFR 112.7 (h) – Tank Car and Tank Truck Loading/Unloading.....	16
40 CFR 112.7 (i) – Field-Constructed Tanks.....	16
40 CFR 112.7 (j) – Other Requirements.....	16
40 CFR 112.8 (a) – General Requirements.....	17
40 CFR 112.8 (b) – Facility Drainage.....	17
112.8 (b) (1) Restrain Drainage from Diked Areas.....	17
112.8 (b) (2) Type of Valves.....	17
112.8 (b) (3) Undiked Areas Drainage Systems.....	17
112.8 (b) (4) Diversionary Systems.....	17
112.8 (b) (5) Drain Water Treatment.....	17
40 CFR 112.8 (c) – Bulk Storage Tanks.....	17
112.8 (c) (1) Compatible Materials of Construction.....	17
112.8 (c) (2) Integral Secondary Containment.....	17
112.8 (c) (3) Discharge of Rainwater from Diked Areas.....	18
112.8 (c) (4) Protect Buried Tanks.....	18
112.8 (c) (5) Protect Bunkered Tanks.....	18
112.8 (c) (6) Test Each Aboveground Tank.....	18
112.8 (c) (7) Leakage from Heating Coils.....	18
112.8 (c) (8) Good Engineering Practice.....	18
112.8 (c) (9) Effluent Treatment Systems.....	18
112.8 (c) (10) Correct Visually Evident Releases.....	19
112.8 (c) (11) Mobile Containers.....	19
40 CFR 112.8 (d) – Transfer Operations, Pumping, And In-Plant Processes.....	19

Table of Contents (cont.)

ATTACHMENT 1: FACILITY DRAWING

ATTACHMENT 2: TRAINING RECORDS

ATTACHMENT 3: INSPECTION PROCEDURES AND FORMS

ATTACHMENT 4: INFORMATION ON FEDERAL AND WISCONSIN SPILL REPORTING REQUIREMENTS

ATTACHMENT 5: SUBSTANTIAL HARM CRITERIA CHECKLIST

ATTACHMENT 6: COMPLIANCE ACTION ITEMS AND SCHEDULE

ATTACHMENT 7: TABLE 1 – OIL STORAGE AND USE

GENERAL DESCRIPTION

The Stoughton Municipal Utilities provides the City of Stoughton and the surrounding area with electrical distribution services. The utility purchases its electrical power from third party energy-producing companies, and does not generate any of its own electrical power. The primary areas where oil is used or stored in quantities in excess of 1,320 gallons include electrical substations and the combined Stoughton utilities office and storage facility. Since this utility shares a storage facility with Water and Wastewater utilities, this plan also incorporates all entities that are located on the same contiguous property with the utilities office and storage. The facility is located at:

600 South Fourth Street
Stoughton, WI 54154

This SPCC plan addresses the:

1. Main office and storage facility, which includes: (2,021-gallons)
 - Transformer storage (246-gallons)
 - Lube oil in 55-gallon drums (275-gallons)
 - 500-gallon AST containing gasoline
 - 1,000-gallon AST containing diesel fuel
2. NORTH Substation (5,539-gallons)
3. SOUTH Substation (6,182-gallons)
4. EAST Substation (2,854-gallons)
5. Wastewater Treatment Plant (2,050-gallons)
 - 1,500-gallon AST containing diesel for back-up generator
 - Lube oil in 55-gallon drums (275-gallons)

Total regulated oil (storage and in-use) at each facility is provided in parentheses in the listing above. Refer to Table 1 in attachment 7 for a detailed listing of equipment and oil quantities.

There are a number of pieces of electrical equipment stored in the electrical utility storage area that are not regulated under 40 CFR 112, and are not required to have secondary containment or diversionary structures. These include all items that are able to hold less than 55 gallons of oil.

Section 112.7 (h) requires that non-transportation-related loading and unloading of trucks used for transport of oil and oil-related products have certain spill safeguards. Stoughton Municipal Utilities does not load or unload trucks, and therefore, this requirement does not apply. Stoughton Municipal Utilities receives shipments from a firm engaged in the transportation and sale of diesel and gasoline products.